

# **EC–CERTIFICATE OF CONFORMITY**

## **0432 –CPD – 0018**

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

### **Emergency exit devices Abloy,**

emergency exit devices operated by a lever handle for single leaf doors  
as detailed on appendix 2,

placed on the market by

**Abloy Oy**  
**Wahlforssinkatu 20**  
**FIN-80101 Joensuu**  
**Finland**

and produced in the factory

**see annex1**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body – 0432 MPA NRW - has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

**DIN EN 179 : 2008-04**  
**(EN 179:2008 (D))**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 19.02.2010 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Dortmund, 17. February 2012



Dipl.-Ing. H. Jansen  
headr of the certification body

---

THIS CERTIFICATE COMPRISES ONE (1) PAGE AND THREE (3) APPENDIXES  
This document was originally written in German. In case of doubt the German version shall prevail.

Emergency exit devices **Abloy**

**manufacturing plants**

product	manufacturing plant
locks	Abloy Oy Wahlforssinkatu 20 FIN-80101 Joensuu Finland
handles	<p>FSB Franz Schneider Brakel GmbH Nieheimer Straße 38 D-33034 Brakel Germany DO 20.3</p> <p>-----</p> <p>ASSA ABLOY Sicherheitstechnik GmbH Werk Berlin (IKON) Goerzallee 299 D-14167 Berlin Germany DO 20.15</p> <p>-----</p> <p>HEWI Heinrich Wilke GmbH Prof.-Bier Str.1-5 D-34442 Bad Arolsen Germany DO 20.13</p> <p>-----</p> <p>Sapex International AB Kungegårdsgatan 7 S-34442 Alingsås Sweden DO 20.32</p> <p>-----</p> <p>Abloy Oy Wahlforssinkatu 20 FIN-80101 Joensuu Finland DO 20.33</p>



# MATERIALPRÜFUNGSAMT NORDRHEIN-WESTFALEN


Emergency exit devices in accordance to EN 179 for single and double leaf-doors

named:

## Emergency exit devices Abloy

### Single leaf door locks

Item no.	VS-type	Function	Backset	Entraxe	Forend width	Classification										Drk
						3	7	6	B*)	1	3	4	2	A	B	
EL060 EL062	B	Funktion I	30 - 45 mm	92 mm PZ 94 mm RZ	<sup>3</sup> 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL066 EL068	B	Funktion I	30 - 45 mm	92 mm PZ 94 mm RZ	<sup>3</sup> 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL160 EL162	B	Funktion I	55 - 100 mm	72 mm PZ 74 mm RZ	20 mm, 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL166 EL168	B	Funktion I	55 - 100 mm	72 mm PZ 74 mm RZ	24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL165 MP165	B	Funktion I	50 mm	70 mm PZ	25 mm 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL260 EL262	B	Funktion I	30 - 45 mm	92 mm PZ 94 mm RZ	<sup>3</sup> 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL266 EL268	B	Funktion I	30 - 45 mm	92 mm PZ 94 mm RZ	24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL360 EL362	B	Funktion I	55 - 100 mm	72 mm PZ 74 mm RZ	20 mm, 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL366 EL368	B	Funktion I	55 - 100 mm	72 mm PZ 74 mm RZ	24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL418 EL419	B	Funktion I	30 - 45 mm	92 mm PZ 94 mm RZ	<sup>3</sup> 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL420 EL422	B	Funktion I	30 - 45 mm	92 mm PZ 94 mm RZ	<sup>3</sup> 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL426 EL428	B	Funktion I	30 - 45 mm	92 mm PZ 94 mm RZ	24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
MP418 MP419	B	Funktion I	30 - 45 mm	92 mm PZ 94 mm RZ	24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
MP420 MP422	B	Funktion I	30 - 45 mm	92 mm PZ 94 mm RZ	24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL460 EL462	B	Funktion II	30 - 45 mm	92 mm PZ 94 mm RZ	<sup>3</sup> 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL466 EL468	B	Funktion II	30 - 45 mm	92 mm PZ 94 mm RZ	24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL518 EL519	B	Funktion I	55 - 100 mm	72 mm PZ 74 mm RZ	20 mm, 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL520 EL522	B	Funktion I	55 - 100 mm	72 mm PZ 74 mm RZ	20 mm, 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL526 EL528	B	Funktion I	55 - 100 mm	72 mm PZ 74 mm RZ	24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
MP518 MP519	B	Funktion I	55 - 100 mm	72 mm PZ 74 mm RZ	24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
MP520 MP522	B	Funktion I	55 - 100 mm	72 mm PZ 74 mm RZ	24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL524 MP524	B	Funktion I	50 mm	70 mm PZ	25 mm 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL560 EL562	B	Funktion II	55 - 100 mm	72 mm PZ 74 mm RZ	20 mm, 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL566 EL568	B	Funktion II	55 - 100 mm	72 mm PZ 74 mm RZ	24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5
EL564 MP564	B	Funktion II	50 mm	70 mm PZ	25 mm 24 mm	3	7	6	B*)	1	3	4	2	A	B	1 - 5



**Double leaf door locks**

Item no.	VS-type	Function	Backset	Entraxe	Forend width	Classification										Drk
						3	7	6	B*)	1	3	4	2	A	A	
PE060 PE062	A	Funktion I	30 - 45 mm	92 mm PZ 94 mm RZ	<sup>3</sup> 24 mm	3	7	6	B*)	1	3	4	2	A	A	1 - 5
PE260 PE262	A	Funktion I	30 - 45 mm	92 mm PZ 94 mm RZ	<sup>3</sup> 24 mm	3	7	6	B*)	1	3	4	2	A	A	1 - 5
PE420 PE422	A	Funktion I	30 - 45 mm	92 mm PZ 94 mm RZ	<sup>3</sup> 24 mm	3	7	6	B*)	1	3	4	2	A	A	1 - 5
PE460 PE462	A	Funktion II	30 - 45 mm	92 mm PZ 94 mm RZ	<sup>3</sup> 24 mm	3	7	6	B*)	1	3	4	2	A	A	1 - 5
LE945	C	Funktion I	35 mm	-	<sup>3</sup> 24 mm	3	7	6	B*)	1	3	4	2	A	C	1 - 5

- b) all kinds of cylinders do not have influence on the escape function of the lock.  
function I: constantly working escape door function. Opening is always possible over the handle.  
function II: splitted follower, constantly working escape door function from the inside. Opening is always possible over the interior handle from the inside. The external handle will be coupled by an electronically device.
- VS-type A: lock for a single or a double leaf door: active or inactive leaf.  
VS-type B: lock for a single leaf door.  
VS-type C: lock for a double leaf door: only inactive leaf.  
drk: indicates the valid combination between the lock and the handle.



**Handles**

No.	manufacturer	coding
1	ASSA ABLOY Sicherheitstechnik GmbH Werk Berlin	DO 20.15.01 DO 20.15.02
2	FSB	DO 20.3.01 DO 20.3.02
3	HEWI	DO 20.13.01 DO 20.13.02
4	SAPEX	DO 20.32.01 DO 20.32.02
5	ABLOY OY	DO 20.33.01 DO 20.33.02

**\*) fire behaviour**

1.	Test report No. RTE1202/04 VTT.
2.	Statement No. RTE305/02 VTT
3.	Statement No. RTE827/05 VTT
4.	Statement No. RTE1238/05 VTT
5.	Test report No. VTT-S-2313-06
6.	Test report No. VTT-S-3405-06
7.	Statement No. VTT-S-5855.07



**alternative and additional equipments****1. escape route security**

product	manufacturer
GfS EH door guard	GfS Gesellschaft für Sicherheitstechnik mbH Tempowerkring 15 21079 Hamburg

